

Hauptverwaltung Erfurt
(Head Office)
Melchendorfer Straße 64
99 096 Erfurt

phone 0361 / 4 28 30
fax 0361 / 373 55 62

Service-Center Mittelthüringen
Ichtershäuser Str.32
99 310 Arnstadt
phone 03628 / 59 83 70
fax 03628 / 59 83 71

Service-Center Südthüringen
Am Köhlersgehäu 58
98 544 Zella-Mehlis
phone 03682 / 45 2-634
fax 03682 / 45 26 57

Certificate (English Issue)

Test number: **EP-06/2015**

Order: 1AU-48595

Applicant: GEZE GmbH
Reinhold-Vöster-Straße 21-29
71229 Leonberg

Product: Fittings for sliding doors

Type: „GEZE sliding fitting Rollan 40 NT“

Test Centre Association for Technical Inspection (TÜV) Thüringen e.V.
Test Centre for Building Industry Products
Am Köhlersgehäu 58
98544 Zella-Mehlis

Test Report No.: **EP-06/2015**

Test specifications: DIN EN 1527: 2013-03
DIN EN 1670: 2007-06 + Corrigendum 2008-07

Test result: The tested fittings are DIN EN 1527: 2013-03 classified as follows:

numeral	1	2	3	4	5	6	7	8	9
class	--	4	1	--	1	1	--	1	3


Additions: Test report No.: EP-06/2015 (5 pages report, 1 page Annex 01)

Issue date: 06/11/2015

Note: The classification applies only to the audited fittings. Statements concerning quality and properties of other fittings cannot be extrapolated.

Zella-Mehlis, 2016-03-07

Association for Technical Inspection (TÜV) Thüringen e.V.
Test Centre for Building Industry Products


Graduate engineer (FH) Reichelt
Head of the testing centre

